CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 3774-0923:0103 Page 1 of 1

CATEGORY: 3774 -- ELECTRIC LOCKS

LISTEE: SECURITRON MAGNALOCK550 Vista Blvd, Sparks, NV 89434

Contact: Erik Strauss (775) 355-5625 Fax (775) 355-5638

Email: eriks@securitron.com

DESIGN: Models XP-1 and XP-1F exit locking system. System consists of the following

subassemblies:

BPS-12, -1, -3, -4.5, -6, -9, -15; BPS-24, -1, -2, -3, -4, -6, -10; *BPSM-12-6, *-9, *-15; or

*BPSM-24-4, *-6, *-10 Class 2 output power supplies

TSB-1, TSB-3, or XMS exit device (XP-1F requires 3100, 3300, 3600, 3700)

Series 32, 34, *38, 62, *68, and 82 or SAM Series locking device Models TSH-BK and TSH-CL Touch Sense Handle exit device

LCP Lock Control Panel

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 120 VAC, Output: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances,

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as electric locking system. Model XP-1 is intended for installation on non-fire rated

doors. Model X-1F is intended for installation on wood or metal fire rated doors. Authority

having jurisdiction shall be consulted prior to installation.

NOTE: Both models may be used in conjunction with a separately listed fire alarm control panel,

however, the units must be connected via the panels dry relay contacts designated a "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is

NOT approved.

*Rev. 04-19-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2010 Listing Expires June 30, 2011

Authorized By: FRANCIS MATEO, Program Coordinator

Fire Engineering Division